

Name:- Matoshri Academy, Mhasrul , Tal. Nashik, Dist. Nashik

Address:- Mhasrul, Tal. Nashik, Dist. Nashik

Location:- Matoshri Academy , Mhasrul

CollectedDate:-16/07/2025

ReportingDate:-27/07/2025

**REPORT OF WATER TESTING**Sample Collected At : Laboratory Sample
:- Water (Drinking Water)COLLECTED ON 16th of July 2025**I. Chemical Testing**

Sr.No.	Test Parameter	Unit	Result	Acceptable limit	Permissible limit in absensc alternate source
1	Colour	Colours Units	BDL(DL5)	5	15
2	Odour	—	Agreeble	Agreeble	Agreeble
3	pH	—	7.68	6.5-8.5	No relaxation
4	Turbidity	NTU	BDL(DL0.1)	1	5
5	Total Dissolved Solids	mg/l	380	500	2000
6	Total Alkalinity as CaCO ₃	mg/l	201	200	600
7	Total hardness as CaCO ₃	mg/l	214	200	600

Dr.Kishor Khodke
[MD]
Consultant Histopathologist & HematologistDr.Ashwini Khodke
[MBBS, DPB]
Consultant Pathologist0253 251980 Lab Supervisor
+91 845924278114 /A, Surya Arcade , Opp.Nimani Bus Stand,
Panchawati , Nashik -422003 . Maharashtra
prathamesh000111@gmail.com
www.prathameshdiagnostics.com

Name: Matoshri Academy, Mhasrul, Tal. Nashik, Dist. Nashik

ULRNo:TC74772100000282F

TestReportNo:EL221131NW001

TypeofSample:Water(DrinkingWater)

DateOfReporting:27/07/2025

II – Biological Testing

1. Water (Drinking Water)

Sr.No	Test Parameter	Unit	Result	Acceptible limit	Permissible limit in absence of alternate source	Test Method
1	Total coliform	CFU/100ml	Absent	Absent	—	IS:15185
2	E. coli	CFU/100ml	Absent	Absent	—	IS:15185

Remarks :

*The result might be affected due to collection of sample in plastic bottle

OTHER INFORMATION**Abbreviation:**

ULR: Unique Lab Report, BDL: Below Detection Level, NA: Not

Applicable Terms & Conditions : Please refer terms and conditions on backside of Test Report (page 1)

End of Report

Dr.Kishor Khodke
[MD]
Consultant Histopathologist & HematologistDr.Ashwini Khodke
[MBBS, DPB]
Consultant Pathologist

Lab Supervisor