

PUBLIC HEALTH SERVICES



GOVT. OF MAHARASHTRA

JUNIOR SCIENTIFIC OFFICER,

DISTRICT PUBLIC HEALTH LABORATORY, NASHIK.

Civil Hospital Campus, Trimbak Road, Nashik - 422001

E-mail: dphlnasik@gmail.com

Phone:- 0253-2570613

• REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE •

Sender's Name:- PRINCIPAL MATOSHRI ACADEMY (Santosh Education Society's)

Address :- Shri Ram Nagar, near Airforce Station Borgad, Mhasrul, Nashik

Senders Letter No. & Date :- 25-08-2025

Date of Sample Collection :- 25-08-2025 Laboratory Reference No. :- 08 / 1316/ 43

Date of Arrival at Laboratory :- 25-08-2025

Date of Commencing Examination:- 25-08-2025

Sr. No.	Particulars of Water Samples	Results of Analysis (As per IS 10500:2012)			Remark
		Most Probable Number of bacteria Per 100 ml.			
		Coliforms	Thermotolerant coliforms	<i>E.coli</i>	
1	Filter water (NMC)	0	--	--	<u>Potable</u>
Receipt No :- 5147346		Fee Rs. :- 340/-			Date:- 25-08-2025
Note :- Result/ Report mentioned above is/are of sample/s submitted to this laboratory only.					

Outward No:-

388423-

Date:-

29.8.2025

Bayam
कमिष्ठ वैज्ञानिक अधिकारी
जिल्हा आरोग्य प्रयोगशाळा
नाशिक
